



K50 Pro L2 Process Data AOI Guide, v2 10/30/2019

This document covers the installation and use of an Add-On Instruction (AOI) for the Logix Designer software package from Rockwell Automation. This AOI handles cyclic IO-Link Process Data Out to a Banner K50 Pro L2 device via an IO-Link Master connected to an Allen-Bradley PLC. The AOI covers parsing and display of the K50 Pro L2 device Process Data Out. The AOI has one User Defined Tag data type.

Components

Banner_K50ProL2_PD_v2.L5X

UDT Packaged with the AOI

Banner_K50ProL2_PDO_v2

Other AOIs Available Separately

Banner has AOI files for controlling other Banner IO-Link devices and for a variety of IO-Link Masters. Banner also has AOI files for easily handling Banner device Process Data.

Contents

1. Installation Process 1

2. Configuring the IO-Link Master 3

3. Configuring the AOI..... 4

4. Using the AOI..... 7

Appendix A K50 Pro L2 Process Data 8

Appendix B IO-Link Master Cheat Sheet 9


1. Installation Process

This section describes how to install the AOI in Logix Designer software.



1. Open a project.
2. In the Controller Organizer window, right-click on the Add-On Instruction folder. Select the Import Add-On Instruction option.



3. Navigate to the correct file location and select the AOI to be installed. In this example the "Banner_K50ProL2_PD_v2.L5X" file will be selected. Click the Open button.



4. The Import Configuration window will pop up. The default selection will create all of the necessary items for the AOI. Click the OK button to complete the import process.



5. The AOI is added to the Controller Organizer window and should look like the picture at left.
6. AOI installation into the Logix Designer software complete.

2. Configuring the IO-Link Master

Make an EtherNet/IP connection to the IO-Link Master.

Create an Ethernet communications module for the IO-Link Master device. The controller tags generated include Input (I) and Output (O) Assembly Instances. Each Assembly has a corresponding tag array. Creating this Class 1 EtherNet/IP implicit IO connection will provide the PLC access to the IO-Link device Process Data. Each port on the IO-Link Master is given a dedicated group of I and O registers. See the relevant IO-Link Master User's Guide for more information.

3. Configuring the AOI

1. Add the “Banner_K50ProL2_PD_v2” AOI to your ladder logic program. For each of the question marks shown in the instruction we need to create and link a new tag array. The AOI includes a new type of User Defined Tags (UDT): a custom array of tags meant specifically for this AOI.



2. In the AOI, right-click on the question mark on the line labeled “Banner_K50ProL2_PD_v2”. Click New Tag. Name the new tag. This example uses the name “K50ProL2_IOLM2_7_PD_Status”. The example naming convention accounts for this being a K50 Pro L2 device connected to IO-Link Master #2, port #7, in our program. More masters could be named IOLM1, IOLM3, and different sensors could be connected at other port numbers, etc.

Note that the Data Type is the User-Defined Data Type (UDT) entitled “Banner_K50ProL2_PD_v2”. This custom-made array of registers is specially built to handle the memory needs of this AOI. Click Create to make the tag array.

New Tag

Name: K50ProL2_IOLM2_7_PD_Status Create

Description:

Usage: <controller>

Type: Base Connection...

Alias For:

Data Type: Banner_K50ProL2_PD_v2 ...

Parameter Connection:

Scope: Test

External Access: Read/Write

Style:

☒ Constant

☐ Sequencing

☐ Open Configuration

☐ Open Parameter Connections

3. Now we will right-click on the question mark on the line labeled "Process_Data" in the AOI. Click on "New Tag". Give the tag a name. This example uses the name "K50ProL2_IOLM2_7_PD". Notice that the Data Type is "Banner_K50ProL2_PDO_v2". Click Create.

This array will handle the displaying of the parsed Process Data Out for the K50 Pro L2.

New Tag

Name: K50ProL2_IOLM2_7_PD

Description:

Usage: <controller>

Type: Base Connection...

Alias For:

Data Type: Banner_K50ProL2_PDO_v2

Parameter Connection:

Scope: Test

External Access: Read/Write

Style:

☐ Constant


☐ Sequencing

☐ Open Configuration


☐ Open Parameter Connections

Create Cancel Help

4. The last line in the AOI is a setting to account for byte swapping. In the case of the K50 Pro L2, the Process Data is four bytes long. IO-Link Masters may read each pair of bytes in either order, so this AOI must be ready to perform a byte swap. Enter a “0” or a “1” to toggle this setting. See Appendix B for more information.
5. The final step required before we download and run the K50 Pro L2 Process Data AOI involves a File Synchronous Copy (CPS) instruction. A CPS instruction is added to the AOI rung, after the AOI. This CPS instruction is used to copy Process Data Out from the AOI into the raw Process Data Out registers used by the IO-Link Master. See Appendix B for more information. In this example, we will connect the AOI’s “PDO_DT[0]” to the starting byte location for port 7 in the Process Data Out side. In this example, that is byte 192. The size to be copied is 4 bytes.




Here is what the entire rung looks like when completed.



If a Banner IO-Link Master is being used, setup a Move block. Send a 1 to the Activate Outputs array value (see table for each port’s value). As an example, if port 1 needs the process data outputs active then send a 1 to 181.

| IO-Link Master Port | Activate Outputs |
|---------------------|------------------|
| 1 | 181 |
| 2 | 215 |
| 3 | 249 |
| 4 | 283 |
| 5 | 317 |
| 6 | 351 |
| 7 | 385 |
| 8 | 419 |



The “Banner_K50ProL2_PD_v2” AOI is now ready for use.

4. Using the AOI

The “Banner_K50ProL2_PD_v2” Add-On Instruction has created a group of tags representing the K50 Pro L2 Process Data Out, broken out into its component parts.

Look in the Controller Tags to find the name you used above. This example used the name “K50ProL2_IOLM2_7_PD”. The tag array, seen below, has individual pieces of information instead of 32 unlabeled bits.

One item to note: the default “Animation_Type” of 0 keeps the light OFF. The choices for this variable are 1 = Steady (ON), 2 = Flash, 3 = Two Flash, 4 = Strobe, 5 = Half/Half, 6 = Half/Half Rotate, 7 = Chase, 8 = Demo Mode.

| [-] K50ProL2_IOLM2_7_PD | { ... } | { ... } | | Banner_K50ProL2_PDO_v2 |
|--|---------|---------|---------|------------------------|
| + K50ProL2_IOLM2_7_PD.Animation_Type | 1 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Audible_Mode | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Color_1 | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Color_1_Intensity | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Color_2 | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Color_2_Intensity | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Color_Flash_Rate | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.PDO_DT | { ... } | { ... } | Decimal | SINT[4] |
| + K50ProL2_IOLM2_7_PD.Reserved | 0 | | Decimal | SINT |
| + K50ProL2_IOLM2_7_PD.Rotation_Direction | 0 | | Decimal | SINT |

Appendix A K50 Pro L2 Process Data

The K50 has 4 bytes of Process Data Out, as shown below.

| ProcessDataOut "Process Data Out" id=V_Pd_OutConfigurationT | | | | | | | | | | |
|---|------------|----------------|--|---------------|-------------|-----------------|---------------|-----------------------|-------------|--|
| bit length: 32 data type: 32-bit Record | | | | | | | | | | |
| subindex | bit offset | data type | allowed values | default value | acc. restr. | mod. other var. | excl. from DS | name | description | |
| 1 | 0 | 5-bit UInteger | 0 = Green, 1 = Red, 2 = Orange, 3 = Yellow, 4 = Lime Green, 5 = Spring Green, 6 = Cyan, 7 = Sky Blue, 8 = Blue, 9 = Violet, 10 = Magenta, 11 = Rose, 12 = White, 13 = Custom 1, 14 = Custom 2, 15 = Custom 3, 16 = Custom 4, 17 = Custom 5 | | | | | Color 1 | | |
| 2 | 5 | 3-bit UInteger | 0 = 1.5, 1 = 0.5, 2 = 3.0, 3 = 6.0, 4 = 9.0, 5 = 12.0, 6 = Custom | | | | | Color Flash Rate (Hz) | | |
| 3 | 8 | 5-bit UInteger | 0 = Green, 1 = Red, 2 = Orange, 3 = Yellow, 4 = Lime Green, 5 = Spring Green, 6 = Cyan, 7 = Sky Blue, 8 = Blue, 9 = Violet, 10 = Magenta, 11 = Rose, 12 = White, 13 = Custom 1, 14 = Custom 2, 15 = Custom 3, 16 = Custom 4, 17 = Custom 5 | | | | | Color 2 | | |
| 4 | 13 | 2-bit UInteger | 0 = Off, 1 = On, 2 = Pulse | | | | | Audible Mode | | |
| 5 | 15 | Boolean | false = Counter Clockwise, true = Clockwise | | | | | Rotation Direction | | |
| 6 | 16 | 4-bit UInteger | 0 = Off, 1 = Steady, 2 = Flash, 3 = Two Color Flash, 4 = Strobe, 5 = Half/Half, 6 = Half/Half Rotate, 7 = Chase, 8 = Demo Mode | | | | | Animation Type | | |
| 7 | 20 | 4-bit UInteger | 0 = High, 1 = Low, 2 = Medium, 3 = Custom, 4 = Off | | | | | Color 1 Intensity | | |
| 8 | 24 | 4-bit UInteger | 0 = High, 1 = Low, 2 = Medium, 3 = Custom, 4 = Off | | | | | Color 2 Intensity | | |
| 9 | 28 | 4-bit UInteger | 0 | | | | | Reserved | | |

This Process Data is mapped to a specific group of EtherNet/IP registers. The 32-bits of Process Data actually encode 8 separate pieces of information, as shown above.

This AOI intelligently parses this Process Data into its component pieces.

Appendix B IO-Link Master Cheat Sheet

Different IO-Link Masters behave differently in several ways. For one, the register locations where Process Data is stored varies. For another, some IO-Link Masters require byte-swapping and/or word-swapping. The tables below aim to define some of these differences. Note that these numbers are when using all default settings. IO-Link Masters can change the register locations to which Process Data is mapped in response to non-default, optional settings. See relevant IO-Link Master documentation for more information.

PDI (Process Data In) is found in the IO-Link Master's T->O (PLC "Input") Assembly Instance.

PDO (Process Data Out) is found in the IO-Link Master's O->T (PLC "Output") Assembly Instance.

Table 1. First Register of Process Data "SINT0"

| Port | Allen-Bradley* | | Comtrol | | Balluff | | Turck | | ifm | | Banner | |
|------|----------------|--------------|---------|-----|---------|-----|-------|-----|-----|-----|--------|-----|
| | PDI | PDO | PDI | PDO | PDI | PDO | PDI | PDO | PDI | PDO | PDI | PDO |
| 1 | I.Ch0Data[0] | O.Ch0Data[0] | 4 | 0 | 8 | 6 | 6 | 4 | 190 | 46 | 184 | 182 |
| 2 | I.Ch1Data[0] | O.Ch1Data[0] | 40 | 32 | 56 | 38 | 38 | 36 | 222 | 78 | 218 | 216 |
| 3 | I.Ch2Data[0] | O.Ch2Data[0] | 76 | 64 | 104 | 70 | 70 | 68 | 254 | 110 | 252 | 250 |
| 4 | I.Ch3Data[0] | O.Ch3Data[0] | 112 | 96 | 152 | 102 | 102 | 100 | 286 | 142 | 286 | 284 |
| 5 | I.Ch4Data[0] | O.Ch4Data[0] | 148 | 128 | 200 | 134 | 134 | 132 | 318 | 174 | 320 | 318 |
| 6 | I.Ch5Data[0] | O.Ch5Data[0] | 184 | 160 | 248 | 166 | 166 | 164 | 350 | 206 | 354 | 352 |
| 7 | I.Ch6Data[0] | O.Ch6Data[0] | 220 | 192 | 296 | 198 | 198 | 196 | 382 | 238 | 388 | 386 |
| 8 | I.Ch7Data[0] | O.Ch7Data[0] | 256 | 224 | 344 | 230 | 230 | 228 | 414 | 270 | 422 | 420 |

*see relevant Banner Allen-Bradley IO-Link Master AOI Guide and Allen-Bradley User Guides for more information on using device IODD files to aid in integration.

Note: Murr IO-Link Masters have configurable process data. Refer to the Murr IO-Link Master Instruction Manual for Process Data mappings.

Table 2. Byte-Swap

| IO-Link Master | Byte Swap |
|----------------|-----------|
| Allen-Bradley | 0 |
| Comtrol | 1 |
| Balluff | 0 |
| Turck | 1 |
| ifm | 1 |
| Murr | 0 |
| Banner | 0 |

Specific hardware used in both tables (all default settings):

- Allen-Bradley Armor Block I/O IO-Link Master (1732E-8IOLM12R)
- Comtrol 8-EIP IO-Link Master (99608-8)
- Balluff BNI006A (BNI EIP-508-105-Z015)
- Turck TBEN-L5-8IOL
- ifm AL1122
- Murr Impact67 E DIO 12 DIO4/IOL4 4P (Art.-No. 55144)

Banner IO-Link Masters (DXMR90-4K) have a port status register. The register gives the status of the port. It gives information on if the port has an IO-Link device connected and if Process Data is valid. This is optional information but is useful for troubleshooting. The data comes into the PLC as bytes while the literature shows the value as a word. The table below gives the upper and lower byte data location in the PLC. The upper byte includes bits 15 through 8, while the lower byte has bits 7 through 0.

| IO-Link Master Port | Upper Bits 15 - 8 | Lower Bits 7 - 0 |
|------------------------|----------------------|---------------------|
| 1 | 182 | 183 |
| 2 | 216 | 217 |
| 3 | 250 | 251 |
| 4 | 284 | 285 |
| 5 | 318 | 319 |
| 6 | 352 | 353 |
| 7 | 386 | 387 |
| 8 | 420 | 421 |

Port Status:

Bit0 = Connected?

Bit1 = Process Data Valid?

Bit2 = Event Pending?

Bit3 = Ready for ISDU?

Bit4 = Pin4 SIO State

Bit5 = Pin2 SIO State

Bit6-7 = Pin4 Mode:

SDCI Mode = 0

SIO Input Mode = 1

SIO Output Mode = 2

Bit8-10 = Pin2 Mode:

Disabled = 0

Input Normal = 1

Output = 2

Diagnostic Input = 3

Inverted Input = 4